

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Type B residual current operated circuit-breakers (RCCBs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang China
Name and address of the manufacturer	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	1P+N, 3P+N Ue = 230 / 240 Vac for 1P+N, 400 / 415 Vac for 3P+N, 50 Hz In = 25, 40, 63 A IΔn = 0,03, 0,1, 0,3 A Type B, without time-delay Inc = IΔc = 10000 A Im = IΔm = 500 A and 10 In whichever is greater Safety grid distance "a" = 50 mm Ambient air temperature: - 25 °C ... + 40 °C (-25°C was tested according to EN 61008-1)
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NL210
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This certificate replaces certificate CB no. NL-62305 issued on 2019-11-27. The tests were performed in 2016, 2019 and 2020.
A sample of the product was tested and found to be in conformity with	IEC 61008-1:2010, IEC 61008-1:2010/AMD1:2012, IEC 61008-1:2010/AMD2:2013, IEC 61008-2-1:1990, IEC 62423:2009  National differences: AU 3316987.50
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands


